




Product Service

CERTIFICATE

No. Z2 093522 0012 Rev. 00

Holder of Certificate: **Worldwide Energy and Manufacturing USA Co., Ltd.**
C1room 1708 Nanfung Tower
173 Des Voeux Rd
Central
HONG KONG

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262103703-00

Valid until: 2025-09-07

Date, 2021-03-17

(Zhulin Zhang)



CERTIFICATE

No. Z2 093522 0012 Rev. 00

Model(s): AS-6M144-HC-xxxW, xxx=410 to 450 in step of 5,
AS-6M120-HC-xxxW, xxx=340 to 375 in step of 5,
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
PID test condition:	-1500 V DC,96h, 85°C, 85%RH
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Remark: PID testing method is according to IEC TS 62804-1:2015

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
PPP 58042B:2015